

SWEET HOME SCHOOL DISTRICT
LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Oak Heights	Room #1	1606713-001	6/9/2016	10:02 AM	6/22/2016	1:29 PM	0.0021	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #2	1606713-002	6/9/2016	10:10 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Lower Hall Drinking Fountain	1606713-003	6/9/2016	10:14 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #3	1606713-004	6/9/2016	10:20 AM	6/22/2016	1:29 PM	0.0024	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #4	1606713-005	6/9/2016	10:23 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Boiler Room	1606713-006	6/9/2016	10:25 AM	6/22/2016	10:21 AM	0.0074	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #5	1606713-007	6/9/2016	10:26 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #6	1606713-008	6/9/2016	10:28 AM	6/22/2016	1:29 PM	0.0068	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Lower Hall Boys Rest Room	1606713-009	6/9/2016	10:30 AM	6/22/2016	1:29 PM	0.0023	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Lower Hall Girls Rest Room	1606713-010	6/9/2016	10:33 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Boys RR Drinking Fountain	1606713-011	6/9/2016	11:03 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Upper Hall Drinking Fountain	1606713-012	6/9/2016	11:09 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #8	1606713-013	6/9/2016	11:12 AM	6/22/2016	1:29 PM	0.0062	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #15	1606713-014	6/9/2016	11:16 AM	6/22/2016	1:29 PM	0.0045	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #16	1606713-015	6/9/2016	11:20 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #6 Drinking Fountain	1606713-016	6/9/2016	11:22 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Gym Drinking Fountain	1606713-017	6/9/2016	11:25 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Kitchen	1606713-018	6/9/2016	11:27 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Staff Room	1606713-019	6/9/2016	10:40 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Health Room	1606713-020	6/9/2016	10:42 AM	6/22/2016	1:29 PM	0.0028	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Library	1606713-021	6/9/2016	10:44 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Upper Hall Girls Rest Room	1606713-022	6/9/2016	10:47 AM	6/22/2016	1:29 PM	0.0025	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #9	1606713-023	6/9/2016	10:50 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #10	1606713-024	6/9/2016	10:53 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #11	1606713-025	6/9/2016	10:54 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #12	1606713-026	6/9/2016	10:56 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #13	1606713-027	6/9/2016	10:58 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Oak Heights	Room #14	1606713-028	6/9/2016	10:59 AM	6/22/2016	1:29 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Junior High	Drinking Fountain - South Green Hall	1606717-001	6/16/2016	10:30 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	East Blue Hall Drinking Fountain	1606717-002	6/16/2016	10:40 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	Staff Room Fridge	1606717-003	6/16/2016	10:45 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	Office Sink kids take med.	1606717-004	6/16/2016	10:51 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	North Red Hall DF	1606717-005	6/16/2016	10:58 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	SW Hall by Gym	1606717-006	6/16/2016	11:20 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	Boys Locker Room Fountain	1606717-007	6/16/2016	11:25 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	Cafeteria DF	1606717-008	6/16/2016	11:34 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Junior High	Classroom 25A DF	1606717-009	6/16/2016	11:40 AM	6/16/2016	3:25 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

**SWEET HOME SCHOOL DISTRICT
LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE**

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Transportation	Kitchen Faucet	1608883-005	8/18/2016	8:30 AM	8/30/2016	7:18 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Transportation	Mens Restroom	1608883-006	8/18/2016	8:30 AM	8/30/2016	7:18 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Transportation	Womens Restroom	1608883-007	8/18/2016	8:30 AM	8/30/2016	7:18 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Transportation	Bus Garage	1608883-008	8/18/2016	8:30 AM	8/30/2016	7:18 AM	0.0029	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
District Office	Business Office Sink	1608602-003	8/23/2016	9:00 AM	8/11/2016	8:55 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
District Office	Main Hall Drinking Fountain	1608602-004	8/23/2016	9:00 AM	8/11/2016	8:55 PM	0.0052	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
District Office	Maintenance Sink	1608602-005	8/23/2016	9:00 AM	8/11/2016	8:55 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
District Office	Skateboard Park	1608602-006	8/23/2016	9:00 AM	8/11/2016	8:55 PM	0.0098	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Hawthorne	Ball Field	1607809-003	7/18/2016	7:00 AM	7/19/2016	7:44 AM	0.0027	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #1	1606698-001	6/9/2016	9:30 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #2	1606698-002	6/9/2016	9:34 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #3	1606698-003	6/9/2016	9:37 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #4	1606698-004	6/9/2016	9:40 AM	6/17/2016	8:01 PM	0.0133	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #5	1606698-005	6/9/2016	9:42 AM	6/17/2016	8:01 PM	0.0020	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #6	1606698-006	6/9/2016	9:44 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #7	1606698-007	6/9/2016	9:45 AM	6/16/2016	10:21 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #8	1606698-008	6/9/2016	9:47 AM	6/16/2016	10:21 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #9	1606698-009	6/9/2016	9:49 AM	6/16/2016	10:21 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #10	1606698-010	6/9/2016	9:50 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #16	1606698-011	6/9/2016	10:32 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #17	1606698-012	6/9/2016	10:35 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #18	1606698-013	6/9/2016	10:37 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #19	1606698-014	6/9/2016	10:42 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #27	1606698-015	6/9/2016	10:02 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #25	1606698-016	6/9/2016	10:04 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #24	1606698-017	6/9/2016	10:06 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #23	1606698-018	6/9/2016	10:07 AM	6/17/2016	8:01 PM	0.0036	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #22	1606698-019	6/9/2016	10:08 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #11	1606698-020	6/9/2016	10:20 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #12	1606698-021	6/9/2016	10:28 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #13	1606698-022	6/9/2016	10:30 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #14	1606698-023	6/9/2016	10:32 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Room #15	1606698-024	6/9/2016	10:34 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #21	1606698-025	6/9/2016	10:09 AM	6/17/2016	8:01 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Hawthorne	Drinking Fountain #20	1606698-026	6/9/2016	10:10 AM	6/17/2016	8:01 PM	0.0035	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

**SWEET HOME SCHOOL DISTRICT
LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE**

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Foster	Health Room	1606708-001	6/9/2016	10:42 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Hall Main Building	1606708-002	6/9/2016	10:50 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Library	1606708-003	6/9/2016	10:52 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 13 Outside Fountain	1606708-004	6/9/2016	11:12 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 13	1606708-005	6/9/2016	11:14 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 12	1606708-006	6/9/2016	11:16 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 11	1606708-007	6/9/2016	11:17 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 10	1606708-008	6/9/2016	11:19 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 9	1606708-009	6/9/2016	11:21 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Kitchen	1606708-010	6/9/2016	11:33 AM	6/20/2016	5:37 PM	0.0040	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 8	1606708-011	6/9/2016	11:30 AM	6/20/2016	5:37 PM	0.0021	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 7	1606708-012	6/9/2016	11:32 AM	6/20/2016	5:37 PM	0.0023	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 6 Outside Fountain	1606708-013	6/9/2016	11:34 AM	6/20/2016	5:37 PM	0.0039	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 6	1606708-014	6/9/2016	11:35 AM	6/20/2016	5:37 PM	0.0035	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 5	1606708-015	6/9/2016	11:36 AM	6/20/2016	5:37 PM	0.0044	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 4	1606708-016	6/9/2016	11:38 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 3	1606708-017	6/9/2016	11:41 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 2	1606708-018	6/9/2016	11:43 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 1	1606708-019	6/9/2016	11:44 AM	6/20/2016	5:37 PM	0.0041	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Break Room	1606708-020	6/9/2016	11:46 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 15 Kitchen	1606708-021	6/9/2016	11:50 AM	6/20/2016	5:37 PM	0.0053	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Room 15	1606708-022	6/9/2016	11:53 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Gym	1606708-023	6/9/2016	11:58 AM	6/20/2016	5:37 PM	Not detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Foster	Computer Lab	1606708-024	6/9/2016	12:02 PM	6/20/2016	5:37 PM	0.0035	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
High School	Nurse	1606A20-001	6/16/2016	2:00 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	"A" Staff Room	1606A20-002	6/16/2016	2:02 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	LBCC	1606A20-003	6/16/2016	2:04 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Basic Life Skills	1606A21-003	6/16/2016	1:04 PM	6/22/2016	9:28 PM	0.0032	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	New Gym 1	1606A21-004	6/16/2016	1:06 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	New Gym 2	1606A21-005	6/16/2016	1:08 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Counseling Office	1606A22-001	6/16/2016	1:32 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	A3	1606A22-002	6/16/2016	1:34 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	A4	1606A22-003	6/16/2016	1:36 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Auditorium	1606A22-004	6/16/2016	1:38 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Custodian Office	1606A22-005	6/16/2016	1:40 PM	6/22/2016	9:28 PM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Metals	1609909-001	9/8/2016	9:00 AM	9/22/2016	7:24 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	East C Staff	1606A23-002	6/16/2016	3:07 PM	6/24/2016	9:51 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	C1	1606A23-003	6/16/2016	3:08 PM	6/24/2016	9:51 AM	0.0063	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	C2	1606A23-004	6/16/2016	3:08 PM	6/24/2016	9:51 AM	0.0025	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	West C Staff	1606A23-005	6/16/2016	3:10 PM	6/24/2016	9:51 AM	0.0089	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B1	1607031-001	7/1/2016	8:57 AM	7/3/2016	9:09 AM	0.0100	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

SWEET HOME SCHOOL DISTRICT

LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE

High School	Home Ec B2	1608883-004	8/18/2016	7:08 AM	8/24/2016	12:13 PM	0.0055	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B3	1607031-003	7/1/2016	9:05 AM	7/3/2016	9:09 AM	0.0134	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B4	1607031-004	7/1/2016	9:07 AM	7/3/2016	9:09 AM	0.0089	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B5	1607031-005	7/1/2016	9:09 AM	7/3/2016	9:09 AM	0.0044	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B6	1608602-001	8/10/2016	3:30 PM	8/23/2016	8:55 PM	0.0106	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Home Ec B7	1607031-007	7/1/2016	9:13 AM	7/3/2016	9:09 AM	0.0026	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Wood 1	1606A13-001	6/16/2016	2:45 PM	6/24/2016	4:25 PM	0.0030	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Wood 2	1606A13-002	6/16/2016	2:45 PM	6/24/2016	4:25 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Art	1606A13-003	6/16/2016	2:45 PM	6/24/2016	4:25 PM	0.0075	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	MST	1606A13-004	6/16/2016	2:48 PM	6/24/2016	4:25 PM	0.0026	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Auto E	1606A13-005	6/16/2016	2:50 PM	6/24/2016	4:25 PM	0.0080	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Auto W	1607809-002	7/18/2016	10:01 AM	7/19/2016	7:44 AM	0.0117	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Forestry	1606A13-007	6/16/2016	2:54 PM	6/24/2016	4:25 PM	0.0033	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LP1	1606A13-008	6/16/2016	2:56 PM	6/24/2016	4:25 PM	0.0027	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LP2	1606A13-009	6/16/2016	2:58 PM	6/24/2016	4:25 PM	0.0037	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LP3	1606A13-010	6/16/2016	3:00 PM	6/24/2016	4:25 PM	0.0044	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	W Room	1606A18-001	6/16/2016	1:42 PM	6/25/2016	6:58 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Wgt Room	1606A18-002	6/16/2016	1:44 PM	6/25/2016	6:58 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	GL 1	1606A18-003	6/16/2016	1:46 PM	6/25/2016	6:58 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Concession Stand	1609909-002	9/8/2016	9:05 AM	9/22/2016	7:24 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Pool O	1606A18-005	6/16/2016	1:50 PM	6/25/2016	6:58 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Pool F	1606A18-006	6/16/2016	1:52 PM	6/25/2016	6:58 AM	0.0094	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Kit S	1606A18-007	6/16/2016	1:54 PM	6/25/2016	5:15 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Kit N	1606A18-008	6/16/2016	1:56 PM	6/25/2016	5:15 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Store	1606A18-009	6/16/2016	1:58 PM	6/25/2016	5:15 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	W Nurse	1606A18-010	6/16/2016	1:58 PM	6/25/2016	5:15 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	A1	1606A24-001	6/16/2016	3:22 PM	6/24/2016	9:51 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	A2	1606A24-002	6/16/2016	3:23 PM	6/24/2016	9:51 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Football Field Concession	1606C60-001	6/28/2016	6:39 AM	6/29/2016	5:42 PM	0.0064	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Softball Field Valve Box	1606C60-002	6/28/2016	6:48 AM	6/29/2016	5:42 PM	0.0665	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Varsity Baseball Field	1606C60-003	6/28/2016	6:51 AM	6/29/2016	5:42 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	JV Baseball Field	1606C60-004	6/28/2016	7:04 AM	6/29/2016	5:42 PM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	A12-1	1606C60-005	6/28/2016	7:10 AM	6/29/2016	5:42 PM	0.0148	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	West C Staff 1	1606C60-007	6/28/2016	9:49 AM	6/29/2016	5:42 PM	0.0102	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	Art 1	1606C60-008	6/28/2016	9:03 AM	6/29/2016	5:42 PM	0.0106	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LBCC 1	1608883-001	8/18/2016	6:50 AM	8/30/2016	7:18 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LBCC 2	1608883-002	8/18/2016	6:55 AM	8/30/2016	7:18 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR
High School	LBCC 3	1608883-003	8/18/2016	7:00 AM	8/30/2016	7:18 AM	Not Detectable	0.02000 mg/L	Analytical Laboratory Group, Eugene, OR

*Valve box lid has been screwed shut to prevent access until steps have been taken to reduce the lead level

**SWEET HOME SCHOOL DISTRICT
LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE**

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Crawfordsville	Room 4	1610380-001	10/7/2016	7:05 AM	10/13/2016	8:38 AM	0.0153	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Room 5	1610380-002	10/7/2016	7:07 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Room 8	1610380-003	10/7/2016	7:00 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Staff Room	1610380-004	10/7/2016	7:03 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Kitchen	1610380-005	10/7/2016	6:55 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Holley Elem.	Main Hall N. Drinking Fount.	1610381-001	10/7/2016	6:05 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Holley Elem.	Main Hall W. Drinking Fount.	1610381-002	10/7/2016	6:08 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Holley Elem.	Classroom 2	1610381-003	10/7/2016	6:15 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Holley Elem.	Classroom 6	1610381-004	10/7/2016	6:18 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR
Holley Elem.	Classroom 7	1610381-005	10/7/2016	6:20 AM	10/13/2016	8:38 AM	Not Detectable	0.02000	mg/L	Analytical Laboratory Group, Eugene, OR

Tests prior to 2016:

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Crawfordsville	Room 1	1409375-001	9/5/2014	11:58 AM	9/12/2014	11:22 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Room 3	1409375-002	9/5/2014	12:00 PM	9/12/2014	11:22 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Room 9	1409375-003	9/5/2014	12:04 PM	9/12/2014	11:22 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Room 6	1409375-004	9/5/2014	12:06 PM	9/12/2014	11:22 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Crawfordsville	Storage Room Cust. Closet	1409375-005	9/5/2014	12:08 PM	9/12/2014	11:22 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR

Building	Location	Lab ID #	Date Collected	Time Collected	Date Analyzed	Time Analyzed	Result	Maximum Contaminant		Laboratory
								Level	Units	
Holley	#1	1509831-001	9/18/2015	6:59 AM	10/1/2015	5:19 PM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Holley	Teacher Lounge	1509831-002	9/18/2015	6:48 AM	10/1/2015	5:19 PM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Holley	#3	1509831-003	9/18/2015	6:57 AM	10/1/2015	5:19 PM	0.00649	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Holley	#4	1509831-004	9/18/2015	6:53 AM	10/1/2015	5:19 PM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Holley	#5	1509831-005	9/18/2015	6:51 AM	10/1/2015	5:19 PM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR

SWEET HOME SCHOOL DISTRICT
LEAD TESTING -- MOST RECENT RESULTS FOR EACH FIXTURE

Building	Location	Lab ID #	Date		Time		Result	Maximum Contaminant		Laboratory
			Collected	Collected	Analyzed	Analyzed		Level	Units	
Pleasant Valley	Nursery	1509053-001	9/1/2015	6:00 AM	9/15/2015	8:00 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Pleasant Valley	Room 1	1509053-002	9/1/2015	6:00 AM	9/15/2015	8:00 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Pleasant Valley	Room 3	1509053-003	9/1/2015	6:00 AM	9/15/2015	8:00 AM	0.00234	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Pleasant Valley	Room 5	1509053-004	9/1/2015	6:00 AM	9/15/2015	8:00 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR
Pleasant Valley	Kitchen	1509053-005	9/1/2015	6:00 AM	9/15/2015	8:00 AM	Not Detectable	0.0150	mg/L	Analytical Laboratory Group, Eugene, OR