

## Lead in Water Test Results Summary:

## Oak Heights Elementary

### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated**

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
1 Rm 9 sink	2405462-001	4/30/2024	ND	Low		ND	
2 Rm 14 sink	2405462-002	4/30/2024	ND	Low		ND	
3 Rm 10 sink	2405462-003	4/30/2024	ND	Low		ND	
4 Rm 12 sink	2405462-004	4/30/2024	ND	Low		ND	
5 Rm 12 drinking fountain	2405462-005	4/30/2024	ND	Low		ND	
6 Rm 13 sink	2405462-006	4/30/2024	ND	Low		ND	
7 Rm 8 sink	2405462-007	4/30/2024	9.8	Low		9.8	
8 Rm 11 sink	2405462-008	4/30/2024	2.83	Low		2.83	
9 Rm 15 sink	2405462-009	4/30/2024	ND	Low		ND	
10 Rm 1 sink	2405462-010	4/30/2024	ND	Low		ND	
11 Rm 4 sink	2405462-011	4/30/2024	ND	Low		ND	
12 Rm 5 sink	2405462-012	4/30/2024	11.1	Med		11.1	
13 Rm 2 sink	2405462-013	4/30/2024	ND	Low		ND	
14 Rm 3 sink	2405462-014	4/30/2024	ND	Low		ND	
15 Rm 3 drinking fountain	2405462-015	4/30/2024	ND	Low		ND	
16 Rm 6 sink	2405462-016	4/30/2024	ND	Low		ND	
17 Staff Lunch Rm sink	2405462-017	4/30/2024	ND	Low		ND	
18 Lower Hall Girls RR sink	2405462-018	4/30/2024	ND	Low		ND	
19 Lower Hall Boys RR sink	2405462-019	4/30/2024	ND	Low		ND	
20 Lower Hall N Drinking fountain	2405462-020	4/30/2024	ND	Low		ND	
21 Lower Hall W Drinking fountain	2405468-001	4/30/2024	ND	Low		ND	
22 Lower Hall Custodial Closet	2405468-002	4/30/2024	5.92	Low		5.92	
23 Custodial Office	2405468-003	4/30/2024	ND	Low		ND	
24 N Staff RR sink	2405468-004	4/30/2024	ND	Low		ND	
25 S Staff RR Sink	2405468-005	4/30/2024	ND	Low		ND	
26 Upper Hall Girls RR sink	2405468-006	4/30/2024	ND	Low		ND	

27	Upper Hall Boys RR sink	2405468-007	4/30/2024	ND	Low	ND
28	Upper Hall Custodial Closet sink	2405468-008	4/30/2024	31.3	High	31.3
29	Gym Kitchen sink	2405468-009	4/30/2024	ND	Low	ND
30	Gym Boys RR Spigot	2405468-010	4/30/2024	2.33	Low	2.33
31	Gym Boys RR sink	2405468-011	4/30/2024	ND	Low	ND
32	Gym Girls RR Spigot	2405468-012	4/30/2024	ND	Low	ND
33	Gym Girls RR sink	2405468-013	4/30/2024	ND	Low	ND
34	Upper Hall SW Drinking fountain	2405468-014	4/30/2024	ND	Low	ND
35	Upper Hall SE Drinking fountain	2405468-015	4/30/2024	ND	Low	ND
36	Gym Drinking fountain	2405468-016	4/30/2024	ND	Low	ND
37	Room 16 sink	2405468-017	4/30/2024	ND	Low	ND
38	Room 16 RR sink	2405468-018	4/30/2024	ND	Low	ND
39	Room 16 Drinking fountain	2405468-019	4/30/2024	ND	Low	ND

Lead in Water Test Results Summary:		Crawfordsville					
<b>Notes:</b> <ul style="list-style-type: none"><li>The lead in water Action Level is 15 parts per billion (ppb).</li></ul> <b>Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated</b> <ul style="list-style-type: none"><li>A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.</li></ul>							
<b>Legend:</b> <ul style="list-style-type: none"><li>Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.</li><li>Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.</li></ul>							
Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
Boys Bath L sink	2404A73-001	4/29/2024	ND	Low		ND	
Boys Bth R sink	2404A73-002	4/29/2024	ND	Low		ND	
Girls Bath L sink	2404A73-003	4/29/2024	ND	Low		ND	
Girls Bath R sink	2404A73-004	4/29/2024	ND	Low		ND	
Room 5	2404A73-005	4/29/2024	2.18	Low		2.18	
Room 6	2404A73-006	4/29/2024	ND	Low		ND	
Mtg Room sink	2404A73-007	4/29/2024	ND	Low		ND	
Kitchen sink L	2404A73-008	4/29/2024	ND	Low		ND	
Kitchen sink R	2404A73-009	4/29/2024	ND	Low		ND	

## Lead in Water Test Results Summary:

**Foster Elementary****Notes:**

- The lead in water Action Level is 15 parts per billion (ppb).

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated**

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

**Legend:**

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
1 Admin Water fountain 1	2405458-001	4/30/2024	ND	Low		ND	
2 Admin Water fountain 2	2405458-002	4/30/2024	2.57	Low		2.57	
3 Staff Break room	2405458-003	4/30/2024	ND	Low		ND	
4 Admin Rm 1	2405458-004	4/30/2024	5.1	Low		5.1	
5 Courtyard Fountain	2405458-005	4/30/2024	ND	Low		ND	
6 Rm 2	2405458-006	4/30/2024	ND	Low		ND	
7 Rm 3	2405458-007	4/30/2024	ND	Low		ND	
8 Rm 5	2405458-008	4/30/2024	ND	Low		ND	
9 Rm 6	2405458-009	4/30/2024	ND	Low		ND	
10 Rm 7	2405458-010	4/30/2024	5.51	Low		5.51	
11 Rm 8	2405458-011	4/30/2024	ND	Low		ND	
12 Rm 11	2405458-012	4/30/2024	ND	Low		ND	
13 Rm 10	2405458-013	4/30/2024	ND	Low		ND	
14 Rm 9	2405458-014	4/30/2024	ND	Low		ND	
15 Rm 4	2405458-015	4/30/2024	ND	Low		ND	

## Lead in Water Test Results Summary:

**Junior High School****Notes:**

- The lead in water Action Level is 15 parts per billion (ppb).

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated**

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

**Legend:**

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

	Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
	[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
1	Staff Rm	2405461-001	4/30/2024	ND	Low		ND	
2	Red Hall 304	2405461-002	4/30/2024	ND	Low		ND	
3	303	2405461-003	4/30/2024	ND	Low		ND	
4	302	2405461-004	4/30/2024	ND	Low		ND	
5	305	2405461-005	4/30/2024	ND	Low		ND	
6	306	2405461-006	4/30/2024	ND	Low		ND	
7	301	2405461-007	4/30/2024	ND	Low		ND	
8	307	2405461-008	4/30/2024	ND	Low		ND	
9	Library	2405461-009	4/30/2024	ND	Low		ND	
10	Gray Hall Drinking	2405461-010	4/30/2024	ND	Low		ND	
11	Office Sink	2405461-011	4/30/2024	ND	Low		ND	
12	Office Health Rm	2405461-012	4/30/2024	ND	Low		ND	
13	101 Classroom	2405461-013	4/30/2024	ND	Low		ND	
14	103 Classroom	2405461-015	4/30/2024	15.2	High		15.2	
15	104 Classroom	2405461-016	4/30/2024	ND	Low		ND	
16	105 Classroom	2405461-017	4/30/2024	ND	Low		ND	
17	Blue Hall Girls RR	2405461-018	4/30/2024	ND	Low		ND	
18	Blue Hall Boys RR	2405461-019	4/30/2024	ND	Low		ND	
19	Red Hall Boys RR	2405465-002	4/30/2024	ND	Low		ND	
20	Staff Womans RR	2405465-005	4/30/2024	ND	Low		ND	
21	Staff Mens RR	2405465-006	4/30/2024	ND	Low		ND	
22	Green Hall Drinking Fountain	2405465-007	4/30/2024	ND	Low		ND	
23	Red Hall Fountain	2405465-009	4/30/2024	ND	Low		ND	
24	Blue Hall Rm 201	2405465-010	4/30/2024	ND	Low		ND	
25	Blue Hall Rm202	2405465-011	4/30/2024	ND	Low		ND	
26	Blue Hall Rm 203	2405465-012	4/30/2024	ND	Low		ND	
27	Blue Hall Rm 204	2405465-013	4/30/2024	ND	Low		ND	
28	Blue Hall Rm 205	2405465-014	4/30/2024	2.29	Low		2.29	
29	Blue Hall Rm 206	2405465-015	4/30/2024	ND	Low		ND	
30	Blue Hall Rm207	2405465-016	4/30/2024	ND	Low		ND	

31	Blue Hall Rm208	2405465-017	4/30/2024	ND	Low		ND	
32	Girls Green Hall RR	2405881-001	5/14/2024	ND	Low		ND	
33	Green Hall Boys RR	2405881-002	5/14/2024	4.7	Low		4.7	
34	Green Hall 102	2405881-003	5/14/2024	ND	Low		ND	
35	Blue Hall Drinking Fountain	2405881-004	5/14/2024	ND	Low		ND	
36	Red Hall Girls RR	2405881-005	5/14/2024	ND	Low		ND	

### Lead in Water Test Results Summary:

### Holley Elementary

#### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated**

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

#### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

	Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
	[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
1	Hall Drink	2404A74-001	4/25/2024	ND	Low		ND	
2	Office	2404A74-002	4/25/2024	ND	Low		ND	
3	B-Room	2404A74-003	4/25/2024	ND	Low		ND	
4	No4	2404A74-006	4/25/2024	ND	Low		ND	
5	Washroom	2404A74-007	4/25/2024	3.22	Low		3.22	
6	Front Hose	2404A74-008	4/25/2024	ND	Low		ND	
7	Back Hose	2404A74-009	4/25/2024	ND	Low		ND	
8	No1	2404A74-010	4/25/2024	ND	Low		ND	
9	No2	2404A74-011	4/25/2024	ND	Low		ND	
10	No3	2404A74-012	4/25/2024	ND	Low		ND	
11	Garden Hose	2404A74-013	4/25/2024	ND	Low		ND	
12	Side Hose	2404A74-014	4/25/2024	ND	Low		ND	
13	Kitchen	2404A74-015	4/25/2024	ND	Low		ND	
14	Room 5	2405459-001	5/6/2024	ND	Low		ND	
15	Room 6	2405459-002	5/6/2024	ND	Low		ND	
16	Room 1	2406075-001	6/3/2024	ND	Low		ND	
17	Teacher Lounge	2406075-002	6/3/2024	ND	Low		ND	

18	Room 3	2406075-003	6/3/2024	ND	Low		ND	
19	Room 4	2406075-004	6/3/2024	ND	Low		ND	
20	Room 5	2406075-005	6/3/2024	ND	Low		ND	

<b>Lead in Water Test Results Summary:</b>	<b><i>Pleasant Valley</i></b>
--	-------------------------------

#### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

***Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated***

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

#### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

	Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
	<i>[enter description]</i>	<i>[enter ID #]</i>	<i>[enter date]</i>	<i>[enter result]</i>	<i>[autofill]</i>	<i>[enter date]</i>	<i>[enter result]</i>	<i>[autofill]</i>
1	Boys RR 1	2404A71-004	4/29/2024	ND	Low		ND	
2	Boys RR 2	2404A71-005	4/29/2024	ND	Low		ND	
3	Girls RR 1	2404A71-006	4/29/2024	ND	Low		ND	
4	Girls RR 2	2404A71-007	4/29/2024	ND	Low		ND	
5	Kit	2404A71-008	4/29/2024	ND	Low		ND	
6	OS Wobblers Play yard Hose	2404A71-009	4/29/2024	7.65	Low		7.65	
7	BB Off Offices	2404A71-010	4/29/2024	4.24	Low		4.24	
8	Rm 1 Sink 1	2404A71-011	4/29/2024	ND	Low		ND	
9	Rm 1 Sink 2	2404A71-012	4/29/2024	24.6	High		24.6	
10	Wobblers Sink 1	2404A71-013	4/29/2024	ND	Low		ND	
11	Wobblers Sink 2	2404A71-014	4/29/2024	ND	Low		ND	
12	Rm 2	2404A71-015	4/29/2024	ND	Low		ND	
13	Rm 3 Sink 1	2404A71-016	4/29/2024	2.75	Low		2.75	
14	Rm 4	2404A71-017	4/29/2024	4.97	Low		4.97	
15	Gym	2404A71-018	4/29/2024	ND	Low		ND	
16	Gym RR	2404A71-019	4/29/2024	ND	Low		ND	
17	Rm 5 Sink 1	2405460-001	5/6/2024	ND	Low		ND	
18	Rm 5 Sink 2	2405460-002	5/6/2024	ND	Low		ND	

19	Rm 5 RR Sink 3	2405460-003	5/6/2024	ND	Low		ND	

### Lead in Water Test Results Summary:

**High School**

#### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated**

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

#### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

	Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
	[enter description]	[enter ID #]	[enter date]	[enter result]	[autofill]	[enter date]	[enter result]	[autofill]
1	A-35	2404A72-001	4/26/2024	2.03	Low		2.03	
2	Aud Lob	2404A72-002	4/26/2024	ND	Low		ND	
3	LBCC 101	2404A72-003	4/26/2024	2.82	Low		2.82	
4	LBCC Print	2404A72-004	4/26/2024	2.16	Low		2.16	
5	LBcc Hall	2404A72-005	4/26/2024	ND	Low		ND	
6	Off Sink 1B	2404A72-006	4/26/2024	ND	Low		ND	
7	Off M	2404A72-007	4/26/2024	ND	Low		ND	
8	Off W	2404A72-008	4/26/2024	ND	Low		ND	
9	SS	2404A72-009	4/26/2024	ND	Low		ND	
10	Com 1	2404A72-010	4/26/2024	ND	Low		ND	
11	Com 2	2404A72-011	4/26/2024	ND	Low		ND	
12	Com 3	2404A72-012	4/26/2024	ND	Low		ND	
13	A East 1	2404A72-013	4/26/2024	ND	Low		ND	
14	A East 2	2404A72-014	4/26/2024	ND	Low		ND	
15	A East 3	2404A72-015	4/26/2024	ND	Low		ND	
16	Kitchen 1	2404A72-016	4/26/2024	ND	Low		ND	
17	Kitchen 2	2404A72-017	4/26/2024	ND	Low		ND	
18	Cleveland N	2404A72-018	4/26/2024	ND	Low		ND	
19	Cleveland S	2404A72-019	4/26/2024	ND	Low		ND	
20	Library	2404A72-020	4/26/2024	ND	Low		ND	
21	W Shop 1	2404A84-001	4/29/2024	ND	Low		ND	

22	W Shop 2	2404A84-002	4/29/2024	ND	Low		ND	
23	BLS Basin	2404A84-003	4/29/2024	ND	Low		ND	
24	BLS K	2404A84-004	4/29/2024	ND	Low		ND	
25	B-7 K1	2404A84-005	4/29/2024	ND	Low		ND	
26	B-7 K2	2404A84-006	4/29/2024	11.6	Low		ND	
27	B-7 K3	2404A84-007	4/29/2024	6.61	Low		ND	
28	B-7 K4	2404A84-008	4/29/2024	14.5	Med		Med	
29	B-7 K5	2404A84-009	4/29/2024	12.3	Med		Med	
30	B-7 K6	2404A84-010	4/29/2024	5.59	Low		ND	
31	CC1	2404A84-011	4/29/2024	ND	Low		ND	
32	CC2	2404A84-012	4/29/2024	ND	Low		ND	
33	Pool F1	2404A84-013	4/29/2024	10.6	Low		ND	
34	Pool F2	2404A84-014	4/29/2024	15	High		High	
35	Pool 0	2404A84-015	4/29/2024	ND	Low		ND	

### Lead in Water Test Results Summary:

**Hawthorne**

#### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

***Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated***

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

#### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

	Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Retest Date	Final Test Result (ppb)	Final Level
	<i>[enter description]</i>	<i>[enter ID #]</i>	<i>[enter date]</i>	<i>[enter result]</i>	<i>[autofill]</i>	<i>[enter date]</i>	<i>[enter result]</i>	<i>[autofill]</i>
1	Room 7 sink	2404A79-001	4/25/2024	ND	Low		ND	
2	Outside DF by RM 7	2404A79-002	4/25/2024	ND	Low		ND	
3	Room 8 sink	2404A79-003	4/25/2024	ND	Low		ND	
4	Room 9 sink	2404A79-004	4/25/2024	ND	Low		ND	
5	DF by Rm 10A	2404A79-006	4/25/2024	ND	Low		ND	
6	DF at Gym	2404A79-008	4/25/2024	ND	Low		ND	
7	Room 11 sink	2404A79-009	4/25/2024	ND	Low		ND	
8	Room 12 sink	2404A79-010	4/25/2024	ND	Low		ND	



9	Room 1 sink DF	2404A79-011	4/25/2024	ND	Low		ND	
10	Room 2 sink DF	2404A79-012	4/25/2024	ND	Low		ND	
11	Room 3 sink DF	2404A79-013	4/25/2024	ND	Low		ND	
12	DF by room 2	2404A79-014	4/25/2024	ND	Low		ND	
13	Computer Room sink	2404A79-015	4/25/2024	ND	Low		ND	
14	Library Sink	2404A79-016	4/25/2024	ND	Low		ND	
15	DF by Office	2404A79-017	4/25/2024	ND	Low		ND	
16	Office Sink	2404A79-018	4/25/2024	ND	Low		ND	
17	Bottle Water in Office	2404A79-019	4/25/2024	ND	Low		ND	
18	Room 6 sink	2404A79-020	4/25/2024	ND	Low		ND	
19	Room 10 sink	2405499-001	5/3/2024	ND	Low		ND	
20	Room 10 sink DF	2405499-002	5/3/2024	ND	Low		ND	
21	Room 13 sink	2404A81-001	4/25/2024	ND	Low		ND	
22	Room 14 sink	2404A81-002	4/25/2024	ND	Low		ND	
23	Room 15 sink	2404A81-003	4/25/2024	ND	Low		ND	
24	Room 16 sink	2404A81-004	4/25/2024	ND	Low		ND	
25	Room 17 sink	2404A81-005	4/25/2024	ND	Low		ND	
26	Room 18 sink	2404A81-006	4/25/2024	ND	Low		ND	
27	Room 19 sink	2404A81-007	4/25/2024	ND	Low		ND	
28	Room 12 DF	2404A81-008	4/25/2024	ND	Low		ND	